

Communication cables used with Vamp range line differential relays

Relay	Option 1	Option 2	Fiber Converter	Cable	Protocol	Protocol port	Protection stages
VAMP259	A	-	Moxa TCF-90	VX048	ANSI85	Remote	Ldb>, Ldb>>
VAMP259	A	-	Moxa TCF-90	VX048	LDP	Remote	Ldb>>
VAMP259	A	-	Moxa TCF-142	VX062	ANSI85	Remote	Ldb>, Ldb>>
VAMP259	A	-	Moxa TCF-142	VX062	LDP	Remote	Ldb>>
VAMP259	A	-	Westermo ODW-720-F1	VX063	ANSI85	Remote	Ldb>, Ldb>>
VAMP259	A	-	Westermo ODW-720-F1	VX063	LDP	Remote	Ldb>>
VAMP259	I	-	Moxa TCF-90	VX055	LDP	Extension	Ldb>>
VAMP259	I	-	Moxa TCF-90	VX065	ANSI85	Remote	Ldb>, Ldb>>
VAMP259	I	-	Moxa TCF-90	VX065	LDP	Remote	Ldb>>
VAMP259	I	-	Moxa TCF-142	VX056	LDP	Extension	Ldb>>
VAMP259	I	-	Moxa TCF-142	VX066	ANSI85	Remote	Ldb>, Ldb>>
VAMP259	I	-	Moxa TCF-142	VX066	LDP	Remote	Ldb>>
VAMP259	-	C	Moxa TCF-90	VX055	LDP	Extension	Ldb>>
VAMP259	-	C	Moxa TCF-90	VX065	ANSI85	Remote	Ldb>, Ldb>>
VAMP259	-	C	Moxa TCF-90	VX065	LDP	Remote	Ldb>>
VAMP259	-	C	Moxa TCF-142	VX056	LDP	Extension	Ldb>>
VAMP259	-	C	Moxa TCF-142	VX066	ANSI85	Remote	Ldb>, Ldb>>
VAMP259	-	C	Moxa TCF-142	VX066	LDP	Remote	Ldb>>
VAMP259	-	C	Westermo ODW-720-F1	VX064	ANSI85	Remote	Ldb>, Ldb>>
VAMP259	-	C	Westermo ODW-720-F1	VX064	LDP	Remote	Ldb>>
VAMP259	-	C	Westermo ODW-720-F1	VX064	ANSI85	Remote	Ldb>, Ldb>>
VAMP259	-	C	Westermo ODW-720-F1	VX064	LDP	Remote	Ldb>>
VAMP59	V	-	Moxa TCF-90	VX048	ANSI85	Remote	Ldb>, Ldb>>
VAMP59	V	-	Moxa TCF-142	VX062	ANSI85	Remote	Ldb>, Ldb>>
VAMP59	V	-	Westermo ODW-720-F1	VX063	ANSI85	Remote	Ldb>, Ldb>>
VAMP59	X	-	Moxa TCF-90	VX048	ANSI85	Remote	Ldb>, Ldb>>
VAMP59	X	-	Moxa TCF-142	VX062	ANSI85	Remote	Ldb>, Ldb>>
VAMP59	X	-	Westermo ODW-720-F1	VX063	ANSI85	Remote	Ldb>, Ldb>>
VAMP59	L	-	Moxa TCF-90	VX048	ANSI85	Remote	Ldb>, Ldb>>
VAMP59	L	-	Moxa TCF-142	VX062	ANSI85	Remote	Ldb>, Ldb>>
VAMP59	L	-	Westermo ODW-720-F1	VX063	ANSI85	Remote	Ldb>, Ldb>>

Schneider Electric

35 rue Joseph Monier
92506 Rueil-Malmaison
FRANCE

Phone: +33 (0) 1 41 29 70 00
Fax: +33 (0) 1 41 29 71 00

www.schneider-electric.com

Publishing: 4/2013

© 2012 Schneider Electric Industries SAS - All rights reserved.
Electrical equipment should be installed, operated, serviced,
and maintained only by qualified personnel. No responsibility
is assumed by Schneider Electric for any consequences
arising out of the use of this material.